



Chaussée de Vilvorde, 156  
Vilvoordsesteenweg 156  
B-1120 Bruxelles/Brussel  
Tel.: 32 (0)2 264 03 60  
Fax: 32 (0)2 268 89 58  
http://www.apragaz.com  
info@apragaz.com



<b>EC TYPE - EXAMINATION</b>		<b>Certificate N°</b> <b>18/GR/4428-1-REV 0</b>
<b>In accordance with module B of Directive 2014/90/EU on Marine Equipment</b>		
<b>Manufacturer</b>	Name	<b>ANAF FIRE PROTECTION S.P.A.</b>
	Address	<b>Via del Commercio 4 IT - 27020 Torre d'Isola (Pavia) ITALY</b>
<b>Brand Applicant</b>	Name	<b>LALIZAS HELLAS</b>
	Address	<b>3 Gounari, 18531 Piraeus GREECE</b>
<b>Concerned Equipment:</b> Portable Fire Extinguishers (Powder Stored Pressure)		
<b>Type:</b> Lalizas 40069X ( X is substituted by a number depending available languages on the label)		
<b>Technical documents :</b> design ref. 32.890F.F000.00/cert.ref.15/IT/3595		
<b>Capacities:</b> 9 kg		<b>Fire Rating :</b> 43A 233B C
<b>Set pressure:</b> max. 15 bar (+60°C)		<b>Test pressure:</b> 22 bar
<b>Service temperature range:</b> min. -30°C / max. +60°C		
<p>The manufacturer is allowed to affix the marine CE mark  (followed by the NoBo identification number and the year of manufacturing) to approved equipment in the conditions described in article 10 of the Directive , only if the requirements stated in module D are fully complied with.</p> <p style="text-align: center;"><b>The approval is valid until 01/02/2025</b></p>		
<p>APRAGAZ, acting within the scope of its notification for the above mentioned Directive, certifies that the types of equipment defined here above are conform to the requirements of the EN 3.7 in force and to the Marine Equipment Directive 2014/90/EU (as amended), on base of the documentation and samples supplied for review and approbation.</p>		
Date : <b>02/03/2020</b>	Name : <b>B.NEVE</b>	Position <b>General Manager</b>
Notified body identification number :	<b>0029</b>	Signature
Notified body stamp :	<p><b>APRAGAZ</b> Belgium Inspecting Authority</p>	
Notified body reference :	<b>17676P000</b>	